













Size: DN 50 to DN 400 (NPS 2" to 16") **Ends:** Flanges R.F. Class 150 (PN20)

Min Temperature: - 29°C

Max Temperature: + 425°C

Max Pressure: 20 Bars

Specifications: Swing check valve

Bolted bonnet

Vertical or horizontal position

Materials: Carbon steel

SPECIFICATIONS:

- · Swing check valve
- Full bore
- · Vertical position with ascendant fluid or horizontal position (respect the flow direction indicated by the arrow)
- Flanges R.F. Class 150 (PN20)
- Carbon steel body
- Bolted bonnet
- Hoisting eye from DN150 to 400 (NPS 6" to 16")
- ½ stellite (Trim 8, seat with stellite)
- Grey painting RAL 7001 color, 60 µm thickness

USE:

- · Water distribution, gas oil, petrochemical, petroleum industry
- Min and max Temperature Ts: 29°C to + 425°C
- · Max Pressure Ps: 20 bars

FLOW COEFFICIENT Kvs:

DN (mm)	50	80	100	150	200	250	300	350	400
NPS (")	2"	3"	4"	6"	8"	10"	12"	14"	16"
Kvs	40.7	92.9	169.6	381.5	685	1076.8	1556.7	1891	2515

PRESSURE / TEMPERATURE RELATION:

(According to AMSE B16-34 for A216 WCB)

Pressure (Bar)	19.6	19.6	17.9	15.8	13.8	11.7	9.6	8.6	7.6	6.5	5.5
Temperature (°C)	-29	38	93	149	204	260	316	343	371	399	425

PRESSURE / TEMPERATURE GRAPH:


(Bar) 20.7 13.8 6.9 0 -29-0 93 149 204 260 316 343 371 399 425 Temperature (°C)

RANGE:

Pressure


Carbon steel swing check valve flanged R.F. Class 150 (PN20) Ref. 373 from DN 50 to DN 400 (NPS 2" to 16")

MATERIALS:




Item	Designation	Materials						
1	Body	ASTM A216 WCB						
2	Seat	ASTM A105 + stellite Gr.6						
3	Disc	ATM A216 WCB + 13Cr						
4	Stem	ASTM A216 WCB						
5	Pin	ASTM A276-420						
6	Support	ASTM A216 WCB						
7	Bonnet gasket	Graphite + SS 304						
8	Bonnet	ASTM A216 WCB						
9	Stud bolt	ASTM A193 Gr B7						
10	Nut	ASTM A194 Gr 2H						
11	Hoisting eye	Steel 1025						
12	Screw	ASTM A193 Gr B7						
13	Nut	ASTM A194 Gr 2H						
14	Washer	ASTM A276-420						

SIZE (in mm):



DN (mm)	50	80	100	150	200	250	300	350	400
NPS (")	2"	3"	4"	6"	8"	10"	12"	14"	16"
ØР	51	76	102	152	203	254	305	337	388
L	203	241	292	356	495	622	699	787	864
Н	152	175	204	293	353	390	432	460	490
Weight (Kg)	17	26	40	73	114	211	263	295	468

FLANGES SIZE CLASS 150 PN20 (in mm):



DN (mm)	50	80	100	150	200	250	300	350	400
NPS (")	2"	3"	4"	6"	8"	10"	12"	14"	16"
øс	92.1	127	157.2	215.9	269.9	323.8	381	412.8	469.9
Ø D	150	190	230	280	345	405	485	535	595
øк	120.7	152.4	190.5	241.3	298.5	362	431.8	476.3	539.8
Nb x Ø L	4 x 19	4 x 19	8 x 19	8 x 22	8 x 22	12 x 26	12 x 26	12 x 29	16 x 29
b	16.3	19.5	24.3	25.9	29	30.6	32.2	35.4	37
е	2	2	2	2	2	2	2	2	2


STANDARDS:

- Fabrication according to ISO 9001 :2008
- DIRECTIVE 97/23/CE : CE N° 0036
 Risk category III module H
- Designing according to API 594
- Pressure tests according to API 598, table 6
- Length according to ASME B16.10, table 1 A15 series
- Flanges R.F. according to ANSI B16.05
- ATEX Group II Category 2 G/2D Zone 1 & 21 Zone 2 &22 (optional marking)
- Approval certificate Russian GOST-R
- Materials according to NACE MR 01-75 on request


ADVICE: Our opinion and our advice are not guaranteed and SFERACO shall not be liable for the consequences of damages. The customer must check the right choice of the products with the real service conditions.

INSTALLATION POSITIONS:

Vertical position (ascendant fluid)



Horizontal position



INSTALLATION INSTRUCTIONS

GENERAL GUIDELINES:

- Ensure that the check valves to be used are appropriate for the conditions of the installation (type of fluid, pressure and temperature).
- Be sure to have enough valves to be able to isolate the sections of piping as well as the appropriate equipment for maintenance and repair.
- Ensure that the valves to be installed are of correct strength to be able to support the capacity of their usage.

INSTALLATION INSTRUCTIONS:

- Remove the disc hold before using.
- Before installing the check valves, clean and remove any objects from the pipes (in particular bits of sealing and metal) which could obstruct and block the valves.
- Ensure that both connecting pipes either side of the check valve (upstream and downstream) are aligned (if they're not, the valves may not work correctly).
- Make sure that the two sections of the pipe (upstream and downstream) match, the check valve unit
 will not absorb any gaps. Any distortions in the pipes may affect the thightness of the
 connection, the working of the check valve and can even cause a rupture. To be sure, place the kit in
 position to ensure the assembling will work.
- If sections of piping do not have their final support in place, they should be temporarily fixed. This is to avoid unnecessary strain on the check valve.
- If there is a direction changing or if there's another material, it's better to take away the check valve so that it is outside the turbulence area (between 3 and 5 times the ND before and after).
- After a pump please refer to norm FD CEN/TR 13932 to install the check valve.
- Respect the flow direction indicated by the arrow